



Cornell University


CORNELL UNIVERSITY ENERGY MASTER PLAN



Tim Peer, Cornell University
Phil Curlett, Levitan & Associates,
Inc.

LEVITAN & ASSOCIATES, INC.

Energy Master Plan (EMP) Study



Cornell University

- ❑ History and Goals
- ❑ Current Thermal Energy Equipment
- ❑ Future Technologies Evaluated
- ❑ Methodology
- ❑ Financial Analysis
- ❑ Strategic Considerations
- ❑ Recommendations

History and Goals




Cornell University

- ❑ Master planning since 1919
- ❑ Drivers for current EMP:
 - Campus growth
 - Capital renewal in Cornell's Central Heating Plant (CHP)
 - Volatile fuel and electric markets
 - Increasing environmental regulation and awareness
 - Need for predictable costs

Steam Load Forecasts



Cornell University




CHP Boilers



Cornell University

Boiler No.	Fuel	Capacity (klb/h)	Boiler Type	Year Installed	Outlet Conditions (psig/°F)
1	Coal	90	Spreader Stoker	1981	400/600
2	#6 Fuel Oil	70	Sterling Vibragate	1959	200/550
5	Natural Gas	100	D Type Package	1965	200/550
6	Natural Gas or #6 Fuel Oil	107.5/ 109.5	D Type Package	1992	400/640
7	Natural Gas or #6 Fuel Oil	107.5/ 109.5	D Type Package	1992	400/640
8	Coal	175	Overfeed Stoker	1949	400/600


Future Technologies Evaluated



Cornell University

- ❑ Package boilers capable of burning natural gas or oil
- ❑ Atmospheric Circulating Fluidized Bed (ACFB) to replace Boiler 8
- ❑ Biomass boiler
- ❑ One or two Gas Turbines (GT) with Heat Recovery Steam Generators (HRSG)

Methodology



Cornell University

- ❑ Statistical analysis of historical fuel and energy prices to determine volatility parameters
- ❑ Statistical analysis of campus loads to determine daily profiles and variability for each season
- ❑ Base scenario forecast of monthly fuel prices delivered to Cornell and nearby electric generators

Methodology (cont.)




Cornell University

- ❑ Consistent forecast of hourly regional electric prices based on chronological simulation model of regional electric market
- ❑ Base scenario forecast of Cornell's steam and electric loads based on monthly building requirements
- ❑ Alternative scenarios reflecting high and low fuel price forecasts and high and low growth projections

Fuel Price Forecast




Cornell University



Electricity Price Forecast




Cornell University



Summer System Heat Rates




Cornell University



System Heat Rate Profiles




Cornell University



Weekly Electric Profiles by Month




Cornell University



Ambient Temperature by Month, Season




Cornell University



Steam and Electric Load Growth Factors



Cornell University




Financial Analysis



Cornell University

- ❑ Simulated 25 years of operation (2007-2031)
- ❑ Used Monte Carlo simulation to capture short term variability and volatility effects on
 - loads
 - fuel prices
 - electric energy market heat rate
 - steam unit availability

Financial Analysis (cont.)



Cornell University

- ❑ Phase 1 screening
 - Package boiler and GT cases have very similar total costs
 - ACFB has higher cost
 - Biomass boiler is the most expensive
- ❑ Phase 2 probabilistic analysis on three types of variables:
 - Short-term
 - Near-term event
 - Long-term

Phase 2 Near-Term Technology Choices




Cornell University

- ❑ Package boilers as needed to meet reliability criterion
- ❑ Single GT for FY2008
- ❑ Two GTs for FY2008
- ❑ Boiler 8 replaced with ACFB boiler for FY2008

Phase 2 Decision Tree




Cornell University



EVA Confidence Intervals – All Variables




Cornell University




Annual Cost Comparison



Cornell University




Strategic Considerations



Cornell University

- ❑ Electric reliability
 - Black start capability for most campus electric loads
 - Benefits of “islanded” operation

Recommendations



Cornell University

- ❑ Replacing Boiler 8 with Biomass or ACFB does not make sense
- ❑ Most attractive initial choice is installation of single 14 MW GT with infrastructure to support second GT in future